

Certificate

Registration No.: PV 60030365

Page 1

Report No.: 15032952.001

License Holder:
Sunenergy Böhne GmbH
Potsdamer Str. 2
32423 Minden
Germany

Product:
PV Module
Type:
SE-M-72
(power range: 160 – 190 Wp in steps of 5 Wp)

SE-M-96
(power range: 200 – 240 Wp in steps of 10 Wp)

Manufacturing Plant:
0010--21143106 001

Basis:

IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

Factory Inspection
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 16 July 2014.

Cologne, 14 May 2010



Dipl.-Ing. M. Adrian